



Del Mar Fire Department Self-Inspection Checklist

Directions: Walk through your business and mark **OK** or **NO** for each inspection item.
 All items marked **NO** are required to be corrected/repared by business/property owner.
 When complete email to dminspections2020@delmar.ca.us

BUSINESS INFORMATION			
Business Name		Business Phone	
Business Address		Business License #	
Contact Name		Contact Phone	

OK	NO	FIRE INSPECTION CHECKLIST	CODE SECTION
		ACCESS	
		Address numbers and suit numbers shall be plainly visible with a contrast background.	2019 CFC Sec 505.1
		Designated Fire Lanes, & Red curbs shall be labeled, and unobstructed at all times.	2019 CFC Sec 503.3/504.3
		Access to fire protection equipment, hose connections, and hydrants are not obstructed.	2019 CFC Sec 912.4
		EXITS	
		Exit doors shall not be obstructed or blocked in any manner.	2019 CFC Sec 1031
		Emergency exit lighting shall be maintained.	2019 CFC Sec 1008
		The maximum occupant load sign shall be posted when the occupant load is over 50.	2019 CFC Sec 1004.9
		ELECTRICAL	
		Extension cords shall not be used for permanent wiring/remove multiplug adapters.	2019 CFC Sec 604.5
		Multi plug adapters shall be surge protected.	2019 CFC Sec 604.4
		Electrical outlets shall have a cover plate.	2019 CFC Sec 604.6
		All fire extinguishers shall be serviced once a year.	Title 19, Div1, Ch.3, Article 6, Sec 575.1
		FIRE PROTECTION SYSTEMS	
		Fire Sprinkler Systems are serviced and have certification. DATE OF SERVICE:	2019 CFC Sec 901.6
		Kitchen hood system cleaned and serviced within the past 6 Months. DATE ON TAG:	2019 CFC Sec 607.3.3.1
		Fire Alarm Systems shall be tested every 12 Months. DATE OF SERVICE:	2019 CFC Sec 907.8
		A 2A10BC Fire Extinguisher is accessible every 75 feet. DATE ON TAG:	2019 CFC Sec 906.9
		Fire Extinguishers are fully charged, properly mounted, and serviced within past 12 Months.	Title 19, Div1, 567.1

Del Mar Fire Department Self-Inspection Checklist

OK	NO	FIRE PROTECTION SYSTEMS (Continued)	
		Class K Fire Extinguisher is accessible within 30 feet of cooking operations. DATE ON TAG:	<i>Title 19, Div1, Article 5, Sec 573</i>
		There shall be 18 inches of clearance below sprinkler heads.	2019 CFC Sec 315.3.1
OK	NO	FLAMMABLE & COMBUSTIBLE LIQUIDS	
		All compressed cylinders empty or full, shall be secured at all times.	2019 CFC Sec 5303.5
		All Flammable Liquids are stored only in original containers or approved safety cans.	2019 CFC Sec 5303.1
		All Hazardous Materials shall be properly stored and identified properly.	2019 CFC Sec 5003.5
OK	NO	GENERAL REQUIREMENTS	
		Propane heaters are for outdoor use only, located minimum 5 ft. away from combustibles, awnings, and shade covers.	2019 CFC Sec 603.4.2
		Clear combustibles from electrical rooms, boiler rooms, and mechanical rooms.	2019 CFC Sec 315.3

Any questions, please contact or dinspections2020@delmar.ca.us or visit www.delmar.ca.us/fireinspections for more information.

By checking the box below, I certify under penalty of perjury that I have conducted a fire safety inspection of my business, provided accurate information and have made all necessary corrections.

Name

Date